



Government Of West Bengal
Office Of The Deputy Director
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186210800006

Date: 08-03-2021

From:
Deputy Director
North Zone, HQ Wing,
West Bengal Fire & Emergency Services

To: MAHARAJA COLLEGE OF EDUCATION, RUN BY SRI SRI RAMKRISHNA EDUCATIONAL & WELFARE TRUST.
VILLAGE-MADIAGHAT (SOVANAGAR),PO- EKBORNA,BLOCK-RATUA II, DISTRICT -MALDA,PIN-732204,WEST
BENGAL.

Sub: Recommendation of Fire Safety Certificate for the occupancy of an Existing Construction of G + 3 storied building under group Institutional Building in the name of MAHARAJA COLLEGE OF EDUCATION, RUN BY SRI SRI RAMKRISHNA EDUCATIONAL & WELFARE TRUST at the premises no-Plot No.-421, Khatian No.- 794, Mouza-Sultanpur, J.L.No.- 137 at Village- Madiaghat (Sovanagar), P.O- Ekborna, Block-Ratua II, Dist- Malda, Pin Code- 732204,West Bengal.

This is in reference to your Application No. 0125186210800006, Dated-04-03-2021 regarding the Fire Safety Certificate for the occupancy of an Existing Construction of G+3 storied building under group Institutional Building in the name of MAHARAJA COLLEGE OF EDUCATION, RUN BY SRI SRI RAMKRISHNA EDUCATIONAL & WELFARE TRUST at the premises no- Plot No.- 421, Khatian No.- 794, Mouza-Sultanpur, J.L.No.- 137 at Village- Madiaghat (Sovanagar), P.O- Ekborna, Block-Ratua II, Dist- Malda, Pin Code-732204,West Bengal.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. For every 600 m2 of floor area or part there of one 9 ltr. Water type CO2 with a minimum two extinguishers per compartment / floor of the building.
2. For every 100 m2 of floor area or part thereof 4.5 kg CO2 extinguisher with a minimum 2 nos of extinguishers per room / compartment in Library, Record room etc. shall be installed.

- 3) For every 100 m² of floor area or part there of one 10 kg D.C.P. Extinguisher with a minimum 2 nos. per room / compartment in Laboratory etc. shall be installed.
- 4) One U/G Water Reservoir having capacity 1000 ltr should be provided in the premises..
- 5) All the Teaching and Non- teaching staff, members and the students should have the knowledge to operate the fire extinguishers accordingly and they should always be aware of installed fire safety measure as incorporated in the building.
- 6) It is also necessary to prepare to onsite emergency plan for a college building and practice of fire Drill at regular interval.
- 7) Fire Prevention shall be included in the work education and have a class both theoretical and practical at regular interval.
- 8) Violation any of the above, the Provisional N.O.C. shall be treated as cancelled and legal action may be taken as per F. S. Act.
- 10) This Fire Safety Recommendation / Fire Safety Certificate in connection with Provisional N.O.C. valid for one year from the date of issue.

Deputy Director
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by ABHIJIT
PANDEY
Date: 2021.03.26 08:29:48 IST